UES PROMURA

Current product-code edition

Report: PDL-26.102.05

Product-family identifiers in the following report use the current CFFC and CFEC codes.

This copy includes a UES Promura distributor presentation update dated 27 October 2026. It is not a laboratory reissue.

The original report numbers, dates, test arrangements, measurements and recorded results are retained. Printed report page numbers remain unchanged; this cover adds one PDF page.

Original source copies are retained in the website source archive. Refer to the complete report and the tested arrangement when assessing a proposed installation.

UES Promura - product and technical enquiries

sales@uespromura.com.au | +61 3 9547 5833

www.uespromura.com.au | www.band-it-australia.com.au

TEST REPORT

PDL-26.102.05

DAMSTRALAB
ELECTRICAL POWER TESTING

Client:	Band-it IDEX
Order number:	EL7849
Date of tests:	29th of May 2026
Report code:	TR

Prof. Ir. Damstra Laboratory
P.O. Box 23, 7550 AA Hengelo
Europalaan 210, 7559 SC Hengelo
The Netherlands
+31 (0)74 - 246 43 51
info@damstra-lab.nl
www.damstra-lab.nl

Subject: Cable cleats for electrical installations.

Purpose: Test for resistance to electromechanical forces on cable cleats for electrical installations based on IEC 61914 ed. 3.0 2021-10, clause 9.5.2 and 9.5.3.

Object: Cable cleats for electrical installations.
Manufacturer: Band-it IDEX
Type: CFFC-F0615M***-A900 / CFFC-F0615M***-A900
Configuration: 12

Conclusion: The test results of the performed tests are stated in the table with test results and are shown in the pictures of the tests for resistance to electromechanical forces.

Author: B. Stange
Test Engineer

Checked by: R. Wanschers
Test Coordinator

This report consists of: 13 pages

P.A.H. van Gestel BSc
Manager Prof. Ir. Damstra Laboratory

Hengelo, 01-07-2026

The test results concern only the investigated test objects.

Publication and/or reproduction of the content of this report in any other form than by complete and verbatim text in the language it was originally issued is not allowed without written permission.

Client:	Band-it IDEX	
Address:	4799 Dahlia street CO 80216 Denver United States	
Test location:	Prof. Ir. Damstra Laboratory Hengelo, The Netherlands	
Tested by:	B. Stange	Prof. Ir. Damstra Laboratory
Observed by:	P. Moreno T. Lambert G. Li	Band-it IDEX Band-it IDEX IDEX China

TABLE OF CONTENTS

1 Object identification 3
1.1 Technical data and characteristics 3
2 Test program 4
2.1 Normative document 4
3 Test results 4
Appendix A Tests for the resistance to electromechanical forces 5
A.1 Tables with test results 5
A.2 Test circuit diagram 6
A.3 Pictures of the tests for resistance to electromechanical forces 7
A.4 Oscillograms 8
Appendix B Decision rule, measurement uncertainty and used equipment 13

DOCUMENT CONTROL

Revision	Amendment	By	Date
PDL-26.102.05	Creation	B.S.	17-06-2026

UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

1 Object identification




Photo 1 Cable cleats for electrical installations
Manufacturer: Band-it IDEX
Configuration: 12

1.1 Technical data and characteristics

The technical data and characteristics of the test object are defined by the following parameters as specified by the manufacturer

Test object	Cable cleat for electrical installations
Type	CFFC-F0615M***-A900 / CFFC-F0615M***-A900
Manufacturer	Band-it IDEX
Year of manufacture	2026

Rated characteristics of system

Rated peak withstand current, I_{pk}	30kA

UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

2 Test program

Configuration	Cleat type	Centers between fixed cleats [mm]	Cable formation	Type of cable	Target peak current [kA]	Duration [ms]
12	CFFC-F0615M***-A900 / CFFC-F0615M***-A900	300	Trefoil	Classe 5	30,0	100
Remarks:						

Table 1

2.1 Normative document

IEC 61914:2021 Cable cleats for electrical installations

3 Test results

Configuration	Cleat type	Peak current [kA]	Centres between fixed cleats [mm]	Duration [ms]	Clause	Osc.	Verdict
12	CFFC-F0615M***-A900 / CFFC-F0615M***-A900	30,4 22,5 27,7	300	120	9.5.2	16	Pass
		35,2 26,0 32,0		121		17	
		40,2 28,8 37,3		121		18	
		40,4 29,3 37,8		123	9.5.3	19	
Remarks:							

Table 2

UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

Appendix A Tests for the resistance to electromechanical forces

A.1 Tables with test results

DAMSTRALAB ELECTRICAL POWER TESTING	TABLE WITH TEST RESULTS Short-circuit withstand tests	Date:	Sheet:
	PDL-26.102.05	29-05-2026	SC1

Object: Cable cleats for electrical installations
Manufacturer: Band-it


Test and Osc no	Current				Test voltage	Remarks
	peak [A]	rms [A]	duration [ms]	Energy [I²t]	[V]	
Configuration 12 Cleat type: CFFC-F0615M*** / CFFC-F0615M***-A900 Cable type: Class 5 Cleat spacing: 300 mm						
15	15,8 12,1 14,4	7,96 7,99 8,07	117	-	69,4	Calibration shot
16	30,4 22,5 27,7	15,1 15,2 15,3	120	-	133	9.5.2 Pass No visible disturbance.
17	35,2 26,0 32,0	17,6 17,6 17,8	121	-	155	9.5.2 Pass No visible disturbance.
18	40,2 28,8 37,3	20,1 20,1 20,4	121	-	177	9.5.2 Pass No visible disturbance.
19	40,4 29,3 37,8	20,3 20,3 20,5	123	-	178	9.5.3 Pass Water test at 1000 Vac: Pass No visible disturbance.
Phase values are to be read:	L1(R) Supply → L1(R) object L2(S) Supply → L2(S) object L3(T) Supply → L3(T) object					

UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

A.2 Test circuit diagram

DAMSTRALAB ELECTRICAL POWER TESTING	**TEST CIRCUIT DIAGRAMS** Short-circuit laboratory	Test report: PDL-26.102.05

Three phase circuit



G : Generator
MB : Master Breaker
L : Reactor
R : Resistance
PT : Power Transformer
MS : Making Switch
TO : Test Object
V : Voltage Measurement between phases
A : Current Measurement
F : Fusible element, with current limiting resistance (not attached during earth fault testing)

UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

A.3 Pictures of the tests for resistance to electromechanical forces




Photo 3: Before Osc.15



Photo 4: After Osc.19




Photo 5: After Osc.19

UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.


A.4 Oscillograms

PDL-26.102 Osc015 29-5-2026




UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

PDL-26.102 Osc016 29-5-2026




UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

PDL-26.102 Osc017 29-5-2026




UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

PDL-26.102 Osc018 29-5-2026



UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

PDL-26.102 Osc019 29-5-2026



UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.

Appendix B Decision rule, measurement uncertainty and used equipment

- The decision rule for the statement of conformity is based on “Simple Acceptance” in accordance with IEC Guide 115:2023. This implies that the measurement uncertainty is not considered for the statement of conformity. Unless otherwise required by the standard or requested by the client on the front page of this Test report.

- The measurement uncertainty is available on request.

- The used measurement equipment is calibrated by an ISO/IEC 17025 accredited calibration laboratory and traceable to national and international standards. Information of the used measurement equipment is available on request.

UES Promura | +61 3 9547 5833 | sales@uespromura.com.au
10-12 McWilliam Street, Springvale VIC 3171 | uespromura.com.au
Distributor reference copy. Technical / issuer particulars retained; contact links localised.